# **USER MANUAL**

# Phoenix Multi 120Vac

12/1600/70 12/2500/120 24/1600/40 24/3000/70

# **Phoenix MultiPlus 120Vac**

12/2500/120 24/3000/70

# **Phoenix Inverter 120Vac**

12/1600 12/2500 24/1600 24/3000

VICTRON ENERGY AT ANY TIME



# Copyrights © 2003 Victron Energy B.V. All Rights Reserved


This publication or parts thereof, may not be reproduced in any form, by any method, for any purpose.

For conditions of use and permission to use this manual for publication in other than the English language, contact Victron Energy B.V.

VICTRON ENERGY B.V. MAKES NO WARRANTY, EITHER EXPESSED OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, REGARDING THESE VICTRON ENERGY PRODUCTS AND MAKES SUCH VICTRON ENERGY PRODUCTS AVAILABLE SOLELY ON AN "AS IS" BASIS.

IN NO EVENT SHALL VICTRON ENERGY B.V. BE LIABLE TO ANYONE FOR SPECIAL, COLLATERAL, INCIDENTAL, OR CONSEQUENTIAL DAMAGES IN CONNECTION WITH OR ARISING OUT OF PURCHASE OR USE OF THESE VICTRON ENERGY PRODUCTS. THE SOLE AND EXCLUSIVE LIABILITY TO VICTRON ENERGY B.V., REGARDLESS OF THE FORM OF ACTION, SHALL NOT EXCEED THE PURCHASE PRICE OF THE VICTRON ENERGY PRODUCTS DESCRIBED HEREIN.

Victron Energy B.V. reserves the right to revise and improve its products as it sees fit. This publication describes the state of this product at the time of its publication and may not reflect the product at all times in the future.



# **SAFETY RULES**

#### General

Please familiarise yourself with the safety features and instructions by first reading the documentation supplied with this product before using the equipment. This product has been designed and tested in accordance with international standards. The equipment must be used exclusively for the purpose for which it was designed.

#### WARNING: ELECTRIC SHOCK HAZARD.

The product is used in conjunction with a permanent energy source (battery). Input and/ or output terminals may still be dangerously energised, even when the equipment is switched off. Always switch off the AC supply and the battery before carrying out maintenance or servicing the product.

The product has no internal user-serviceable components. Do not remove the front plate or operate the product if any panels have been removed. All servicing must be undertaken by qualified personnel.

Never use the product where there is a risk of gas or dust explosions. Consult the battery manufacturer's information to ascertain that the product is intended for use in conjunction with the battery. Always comply with the battery manufacturer's safety instructions.

WARNING: Do not lift heavy loads without assistance.

#### Installation

Read the installation instructions in the installation manual before installing the equipment.

This is a Safety Class I product (supplied with a protective earthing terminal). Uninterruptible protective earthing must be provided at the AC input and/ or output terminals. An additional earth point is located externally on the product. Whenever it is likely that the earth protection has been damaged, the product must be turned off and secured against unintended operation; please contact qualified service staff.

Ensure that the DC and AC input cables are fused and fitted with circuit breakers. Never replace a safety component with a different type. Consult the manual to determine the correct component.

Before applying power, ensure that the available power source matches the configuration settings of the product as described in the manual

Ensure that the equipment is used under the correct ambient conditions. Never operate the product in a wet or dusty environment. Ensure there is adequate free space for ventilation around the product and check that the ventilation vents are not blocked

Ensure that the required system voltage does not exceed the product's capacity.


#### **Transport and Storage**

Ensure that the mains power and battery leads have been disconnected before storing or transporting the product.

No liability can be accepted for any transport damage if the equipment is shipped in non-original packaging.

Store the product in a dry environment; the storage temperature must be between -20°C and 60°C.

Consult the battery manufacturer's manual in respect of transport, storage, charging, recharging and disposal of the battery.



## 1 DESCRIPTION

#### 1.1 General

#### Multi-functional (Multi/ MultiPlus only)

The Multi gets its name from the multiple functions it can perform. It is a powerful true sine wave inverter, a sophisticated battery charger that features adaptive charge technology and a high-speed AC transfer switch in a single compact enclosure. Beside these primary functions, however, the Multi has several advanced features that provide a range of new applications as outlined below.

#### Uninterrupted AC power (Multi/ MultiPlus only)

In the event of a grid failure, or shore or generator power being disconnected, the inverter within the Multi is automatically activated and takes over supply to the connected loads. This happens so fast (less than 20 milliseconds) that computers and other electronic equipment will continue to operate without disruption.

#### Virtually unlimited power thanks to parallel operation

Up to 5 units can operate in parallel to achieve higher power output. Five 24/3000/70 units, for example, provide 12,5 kW output power with 350 Amps of charging capacity.

#### Three phase capability

In addition to parallel connection, three units of the same model can be configured for threephase output. But that's not all: up to five sets of three units can be parallel connected for a huge 37,5 kW inverter and 1050 A charger! (Multi/ MultiPlus only)

# PowerControl – Dealing with limited generator or shore side power (Multi/MultiPlus only)

The Multi is a very powerful battery charger. It will therefore draw a lot of current from the generator or shore side supply (nearly 10 A per Multi at 230 VAC). With the Phoenix Multi Control Panel (PMC) a maximum generator or shore current can be set. The Multi will then take account of other AC loads and use whatever is extra for charging, thus preventing the generator or shore supply from being overloaded.

## PowerAssist - Boosting the capacity of shore or generator power

The feature that distinguishes the Phoenix MultiPlus from the standard Multi is PowerAssist. This feature takes the principle of PowerControl to a further dimension allowing the MultiPlus to supplement the capacity of the alternative source. Where peak power is so often required only for a limited period, it is possible to reduce the size of generator needed or conversely enable more to be achieved from the typically limited shore connection. When the load reduces, the spare power is used to recharge the battery.

Note: minimum shore current 4 A or generator capacity 2,5 kW required per MultiPlus.



#### 1.2 Battery Charger (Multi/ MultiPlus only)

#### Adaptive 4-stage charge characteristic: bulk - absorption - float - storage

The Phoenix Multi/I MultiPlus features a microprocessor controlled 'adaptive' battery management system that can be preset to suit different types of batteries. The 'adaptive' feature will automatically optimise the process relative to the way the battery is being used.

#### The right amount of charge: variable absorption time

When only shallow discharges occur (a yacht connected to shore power for example) the absorption time is kept short in order to prevent overcharging of the battery. After a deep discharge the absorption time is automatically increased to make sure that the battery is completely recharged.

#### Preventing damage due to excessive gassing: the BatterySafe mode

If, in order to quickly charge a battery, a high charge current in combination with a high absorption voltage has been chosen, the Multi/ MultiPlus will prevent damage due to excessive gassing by automatically limiting the rate of voltage increase once the gassing voltage has been reached

#### Less maintenance and aging when the battery is not in use: the Storage mode

The storage mode kicks in whenever the battery has not been subjected to discharge during 24 hours. In the storage mode float voltage is reduced to 2,2 V/cell (13,2 V for a 12 V battery) to minimise gassing and corrosion of the positive plates. Once a week the voltage is raised back to the absorption level to 'equalize' the battery. This feature prevents stratification of the electrolyte and sulphation, a major cause of early battery failure.

#### Two outputs to charge 2 battery banks

The Multi/ MultiPlus features 2 outputs, of which 1 can carry the full output current. The second output, limited to approximately 4 A and with a slightly lower output voltage, is intended to top up a starter battery.

#### To increase battery life: temperature compensation


Every Multi/ MultiPlus comes with a battery temperature sensor. When connected, charge voltage will automatically decrease with increasing battery temperature. This feature is especially recommended for sealed batteries and/ or when important fluctuations of battery temperature are expected.

#### Battery voltage sense

In order to compensate for voltage loss due to cable resistance, the Multi/ MultiPlus is provided with a voltage sense facility so that the battery always receives the correct charge voltage.

#### Learn more about batteries and battery charging

To learn more about batteries and charging batteries, please refer to our book 'Electricity on Board' (available free of charge from Victron Energy and downloadable from www.victronenergy.com). For more information about adaptive charging please look under Technical Briefs on our website.



#### 1.3 List of Article Numbers for Accessories

Phoenix Multi control REC020002010
Phoenix Inverter control SDRPPIV
Temperature sensor TI SDRPSENSTI
Conn. kit 3-phase operation MultiPlus EQU000002000
Flat cable for 3-phase connect MultiPlus ASS030003000
Flat cable for parallel connect ASS030063000
UTP Patch lead 5 m ASS030065000
UTP Patch lead 10 m ASS030065010
UTP Patch lead 15 m ASS030065020



# **2 OPERATION**

### 2.1 On/ Off Charger Only Switch

When switched to "on", the product is fully functional. The inverter will come into operation and the LED "inverter on" will light up.

#### Multi/ MultiPlus only:

An AC voltage connected to the "AC in" terminal will be switched through to the "AC out" terminal, if within specifications. The inverter will switch off, the "mains on" LED will light up and the charger commences charging. The "bulk", "absorption" or "float" LEDs will light up, depending on the charger mode.

If the voltage at the "AC-in" terminal is rejected, the inverter will switch on.

When the switch is switched to "charger only", only the battery charger of the Phoenix Multi will operate (if mains voltage is present). In this mode input voltage also is switched through to the "AC out" terminal.

**NOTE**: When only the charger function is required, ensure that the switch is switched to "charger only". This prevents the inverter from being switched on if the mains voltage is lost, thus preventing your batteries from running flat.


#### 2.2 Remote Operation

The Phoenix Multi can be operated with a remote control panel. This control panel is called the Phoenix Multi control panel. The panel has an on-off switch and repeats all indicators of the Multi.

The charger of the Phoenix Multi can be turned off. This can be done by changing the set up configuration or by connecting the Phoenix Inverter remote panel.

The Multi remote control panel can also be used to set the AC input current limit for the PowerControl and PowerAssist functions (See paragraph 1.1)

For remote control of the Phoenix Inverter the Phoenix Inverter panel should be used.



#### 2.3 Special Charger Modes Equalizing

Some batteries may need a regular equalizing charge. To perform an equalizing charge the Phoenix Multi can charge at a higher voltage (1V above the absorption voltage for a 12V battery, 2V for a 24V battery) for a period of one hour. The charger current is then limited to 1/4 of the specified value.

The "bulk" and "absorption" LEDs will flash alternately during this cycle.



The equalizing mode results in a charging voltage that may exceed the maximum voltage of DC consumers. These should be disconnected when performing an equalizing charge.

#### **Forced Absorption**

In some cases it may be necessary to charge the battery at the absorption voltage for a specific period of time. In the Forced Absorption mode, the Phoenix Multi will charge at the normal absorption voltage during the preset maximum absorption period.

The "absorption" LED will light up.

The Phoenix Multi can be switched to one of these modes from the remote panel as well as with the aid of the front switch. A prerequisite is that all switches (front, remote and panel) are switched to "on", and that none are switched to the "charger only" position.

Proceed is as follows to switch the Phoenix Multi to either the equalizing mode or Forced Absorption mode:

**REMARK**: switch quickly from "on" to "charger only" and back. The switch must be switched in such a way that the intermediate position is, as it were, "skipped". If the relevant switch remains in the "off" position for any length of time, you may run the risk that the appliance will be switched off. In that case you will need to start again at step 1. Practice is required, particularly when using the front switch. This is less critical when using the remote panel.

- Ensure that all switches (i.e., front switch, remote switch or remote panel switch if present) are switched to the "on" position.
- Ensure that the Phoenix Multi is charging (an AC input voltage must be present; check that the "mains on" LED and one of either the "bulk", "absorption" or "float" LEDs is illuminated).
- Switch the switch successively to "charger only", "on" and "charger only". NOTE: the switching itself should be done quickly but the interval between switching should be from 1/2 to two seconds.
- The "bulk", "absorption" and "float" LEDs will flash five times. Subsequently, the "bulk", "absorption" and "float" LEDs will each light up for a period of two seconds.
- If the switch is switched to "on" while the "bulk" LED illuminates, the charger switches to the equalizing mode.
- If the switch is switched to "on" while the "absorption" LED illuminates, the charger switches to 'Forced Absorption'.

If the switch is not in the required position after these steps, it can be simply switched one more time. This will not change the charging status.



O Ö	LED off LED flashes					
•	LED illuminate	d				
lnv	erter					
	arger			inv	verter	]
0	mains on		on	•	inverter on	
0	bulk			0	overload	The inverter is switched on and
0	absorption		off	0	low battery	supplies power to the load.
0	float		charger only	0	temperature	
_			•			- -
	arger			inv	erter	
0	mains on	_	on	•	inverter on	The nominal output of the inverter is
0	bulk		off	☼	overload	being exceeded. "overload" LED is
0	absorption		charger	0	low battery	on.
0	float		only	0	temperature	
obe	argor			in	ortor	1
	arger				erter	
0	mains on		on	0	inverter on	The inverter is switched off due to
0	bulk		off	•	overload	overload or a short circuit.
0	absorption		charger	0	low battery	
0	float		only	0	temperature	
cha	arger			inv	erter	]
0	mains on		on	•	inverter on	
0	bulk			0	overload	The battery is almost fully
0	absorption		off	☼	low battery	exhausted.
0	float	_	charger only	0	temperature	
						<u>,</u>
cha	arger			inv	erter/	
0	mains on	_	on	0	inverter on	The investor been existed at eff due to
0	bulk		off	0	overload	The inverter has switched off due to the battery voltage being too low.
0	absorption		charger	•	low battery	, 5 5
0	float		only	0	temperature	

2.4 LED Indications and What They Mean

victron energy

7

charger			inve	erter	
0	mains on	on	•	inverter on	
0	O bulk O absorption		0	overload	The electronics temperature is becoming critical.
0		off charger	0	low battery	becoming chical.
0	float	only	☼	temperature	
	,	,			-
cha	arger		inve	erter	
0	mains on	on	0	inverter on	The inverter has switched off due to
0	bulk	off	0	overload	the electronics temperature being
0	absorption	charger	0	low battery	too high.
0	float	 only	•	temperature	
					<b>1</b>
cha	arger		inve	erter	-If the LEDs are flashing alternately,
cha O	arger mains on	on	inve	erter inverter on	the battery is nearly exhausted and
	•		inve		the battery is nearly exhausted and the nominal output is being exceeded.
0	mains on	off	•	inverter on	the battery is nearly exhausted and the nominal output is being exceeded. -If "overload" and "low battery" flash
0	mains on bulk		•	inverter on overload	the battery is nearly exhausted and the nominal output is being exceeded.
0 0 0	mains on bulk absorption	off charger	• \$\bigotimes \bigotimes \bigoti	inverter on overload low battery temperature	the battery is nearly exhausted and the nominal output is being exceeded. -If "overload" and "low battery" flash simultaneously, the ripple voltage
0 0 0	mains on bulk absorption	off charger	• \$\bigotimes \bigotimes \bigoti	inverter on overload low battery	the battery is nearly exhausted and the nominal output is being exceeded. -If "overload" and "low battery" flash simultaneously, the ripple voltage
0 0 0	mains on bulk absorption float	off charger	• \$\bigotimes \bigotimes \bigoti	inverter on overload low battery temperature	the battery is nearly exhausted and the nominal output is being exceeded. -If "overload" and "low battery" flash simultaneously, the ripple voltage
0 0 0	mains on bulk absorption float	off charger only	•	inverter on overload low battery temperature	the battery is nearly exhausted and the nominal output is being exceededIf "overload" and "low battery" flash simultaneously, the ripple voltage on the battery terminal is too high.  The inverter switched off due to excess ripple voltage on the battery
0 0 0 0	mains on bulk absorption float arger mains on	off charger only	•	inverter on overload low battery temperature erter inverter on	the battery is nearly exhausted and the nominal output is being exceededIf "overload" and "low battery" flash simultaneously, the ripple voltage on the battery terminal is too high.  The inverter switched off due to

Bat	tery Charger					,		
cha	arger			inv	erter			
•	mains on	on			on	0	inverter on	The mains voltage is switched
•	<ul><li>bulk</li></ul>		off	0	overload	through and the charger operates		
0	absorption		charger	0	low battery	bulk mode.		
0	float		only	0	temperature			
ch:	arner			inv	erter	]		
•	charger mains on			0	inverter on	The mains voltage is switched		
	bulk		on	0	overload	through and the charger is charging The set absorption voltage,		
•	absorption		off	0	low battery	however, has not yet been reached		
0	float	_	charger only	0	temperature	(Battery Protection Mode).		
			Only	<u> </u>	tomporataro			
cha	arger			inv	erter			
•	<ul><li>mains on</li><li>bulk</li></ul>		on	0	inverter on	The mains voltage is switched		
0			off charger	0	overload	through and the charger operate		
•	absorption			0	low battery	the absorption mode.		
0	float		only	0	temperature			
- 1-				•		1		
cna	arger				erter			
•	mains on		on	0	inverter on	The mains voltage is switched		
0	bulk		off	0	overload	through and the charger operates in the float mode.		
0	absorption		charger	0	low battery	the hoat mode.		
•	float		only	0	temperature			
cha	arger			inv	erter			
•	mains on		on	0	inverter on	The mains voltage is switched		
☼	bulk		off	0	overload	through and the charger operates in		
☼	absorption		charger	0	low battery	raised absorption.		
0	float		only	0	temperature			

# **Special Indications**

### PowerControl

charger				inverter		
☼	mains on		on	0	inverter on	
0	bulk		off	0	overload	
0	absorption		charger	0	low battery	
0	float		only	0	temperature	

The mains voltage is switched through. The AC output current is equal to the preset maximum input current. The charge current is reduced to 0.

# Power Assist<sup>MultiPlus</sup>

charger				inverter		
•	mains on		on	☼	inverter on	
0	bulk		off	0	overload	
0	absorption			charger	0	low battery
0	float		only	0	temperature	

The mains voltage is switched through but the load requires more current than the preset maximum input current. The inverter now switches on to supply the required additional current.



Serial number:
Distributor:

Victron Energy B.V. The Netherlands General phone: Customer support desk: General and Service fax: Sales fax: +31 (0)36 535 97 00 +31 (0)36 535 97 77 +31 (0)36 531 16 66 +31 (0)36 535 97 40

sales@victronenergy.com http://www.victronenergy.com E-mail: Internet site:

Article number: ISM010055000

Version: 00

Date: 01-01-2003